



CERTIFICATE OF CONFORMITY

This Certificate is issued to

ACO Water Management Pte Ltd

(UEN No.: 202235179N)

2 Shenton Way, #18-01, SGX Centre I, Singapore 068804

For Product Certification Scheme: Type 1b

Product Fire Rated Hatch Door

Brand **ACO**

Model : AAC UNIFACE GS/FR, AAC UNIFACE SS/FR,

AAC SERVOKAT GD/FR

Country of Origin Czech Republic

Product Details : An uninsulated hinged steel access cover on floor

construction

Door thickness: 72.5mm to 100mm

Door leaf infill: Concrete mixture C35/45 or steel plate

with calcium silicate board

Integrity: 120 mins

which has complied with the requirements of the scheme based on the following:

STANDARD(S) **TEST REPORT(S)**

EN 1634-1: 2014 + A1: PAVUS Test Report No.: Pr-20-2.046n-En 2018

PAVUS Assessment Report No.: PKO-23-020

(Clause 1.2 & 1.5)

Detailed configuration and installation shall be referenced to the certified report(s) stated above.

Teo Wee Hwee (Mr)

Program Manager SETSCO Services Pte Ltd

Certificate No Date of Issue Date of Expiry FSP-2025-1795 07/11/2025 06/11/2030

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.